

# Certificate



Registration No.: PV 60098037

Page 2

Report No.: 21223935.002

**License Holder:**

**SRI Savitr Solar PVT Ltd.**

Plot No. F11/D, IDA Gandhi Nagar, Kukatpally,  
Hyderabad - 500037  
India

**Manufacturing Plant:**

**SRI Savitr Solar PVT Ltd.**

Plot No. F11/D, IDA Gandhi Nagar, Kukatpally,  
Hyderabad - 500037  
India

**Product:**

PV Modules

with 6" poly - crystalline cells  
SSS-xxx (260 – 320 in steps of 1, with 72 cells)  
SSS-xxx (215 – 265 in steps of 1, with 60 cells)  
SSS-xxx (195 – 240 in steps of 1, with 54 cells)  
SSS-xxx (170 – 210 in steps of 1, with 48 cells)  
SSS-xxx (130 – 160 in steps of 1, with 36 cells)

with poly - crystalline cut cells  
SSS-xxx (141 – 265 in steps of 1, with 72 cells)  
SSS-xxx (008 – 140 in steps of 1, with 36 cells)  
SSS-xxx (003 – 007 in steps of 1, with 36 cells)

xxx represent output power in Wp

**Basis:**

- IEC 61730-1:2004+A1+A2**  
**IEC 61730-2:2004+A1**  
**EN 61730-1:2007+A1+A2**  
**EN 61730-2:2007+A1**  
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



www.tuv.com  
ID 0000043102

**Remarks:**

- Valid in conjunction with TÜV Rheinland certificate based on IEC EN 61215.
- The above listed PV modules fulfil the requirements of Application **Class A** (Class II acc. to IEC 61140). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The above listed PV modules fulfil the requirements of **fire rating class C**.
- Extension to module type with 72 cells.

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

**The certificate is valid until 24 November 2019.**

Cologne, 1 April 2016

Certification body



Dipl.-Ing. M. Adrian